



Solar district heating conference, Malmö 10.04.2013

DEVELOPMENT OF A SOLAR DISTRICT HEATING ONLINE CALCULATION TOOL


Laure Deschaintre

Steinbeis  
Research Institute  
for Solar and  
Sustainable Thermal  
Energy Systems  
[www.solites.de](http://www.solites.de)

solites

## Development of the tool | Introduction

- Conception phase
- Online tool, user-friendly
- Based on TRNSYS simulations
- Two different configurations available: central and distributed




# Contents



- Development of the tool
  - Distributed system
  - Central system
- Economics and environmental performance

Steinbeis Research Institute  
for Solar and Sustainable  
Thermal Energy Systems  
[www.solites.de](http://www.solites.de)

solites




# The distributed system | Definition



- The solar heating plant feeds into the supply pipe
- The net is theoretically infinite
- All the heat produced at set temperature is fed into the net

# The distributed system | Parameters




- **Collector type:** flat-plate, high temperature flat-plate, evacuated tube, evacuated tube with compound parabolic concentrator (CPC).
- **Climate:** Würzburg, Frankfurt and Hamburg for Germany; Stockholm (SE), Milan (IT) and Barcelona (ES)
- **Operation temperatures:** nine combinations of winter/summer supply temperature and winter/summer return temperature from 70/70/30/40 to 110/90/60/70
- **Collector area, azimuth and slope**

Distributed		
Parameter	Steps	Unit
Collector area	100-200-500-1000-2000-5000-10000-20000-50000	m <sup>2</sup>
Collector azimuth	(-45) - (-30) - (-15) - 0 - 15 - 30 - 45	°
Collector slope	15 - 30 - 45 - 60	°

→ 72 576 TRNSYS simulations

# The distributed system | Parameters




## SDH ONLINE-RECHNER

Zur Startseite


**1 Schritt 1** Eingabe    **2 Schritt 2** Erträge    **3 Schritt 3** Wirtschaftlichkeit & Ökologie    **4 Schritt 4** Ergebnis

### Dezentrale Einspeisung | Eingabe


Standort	Frankfurt	?
Kollektortyp	CPC Kollektor	?
Kollektorfläche in m <sup>2</sup>	300	?
Kollektorausrichtung in Grad	15	?
Kollektorneigung in Grad	20	?
Betriebstemperaturen im Wärmenetz in °C	VL(100/80); RL(30/40)	?





# The distributed system | Results



- Multi-linear interpolation
- Radiation on the collector plane
- Collector plant yield
- Efficiency of the collector plant
- Solar energy delivered to the net
- Heat losses through the connection pipes
- System efficiency




# The distributed system | Results



Solar heat delivered to the net by the distributed system for 1000 m<sup>2</sup> collector area and different combinations of operation temperatures ( $T_{\text{supply, winter}}/T_{\text{supply, summer}}/T_{\text{return, winter}}/T_{\text{return, summer}}$ ), for each location and collector type.

# The central system | Definition



# The central system | Parameters



- **Collector type:** flat-plate, high temperature flat-plate, evacuated tube, evacuated tube with compound parabolic concentrator (CPC).
- **Climate:** Würzburg, Frankfurt and Hamburg for Germany; Stockholm (SE), Milan (IT) and Barcelona (ES)
- **Operation temperatures:** supply/return temperatures 60/30, 70/40, 80/50, 90/60

# The central system | Parameters



- **Collector area, azimuth and slope**
- **Specific storage volume**
- **Specific yearly heat demand**


Central		
Parameter	Steps	Unit
Collector area	100-350-1200-4300-15000-50000	m <sup>2</sup>
Collector azimuth	(-45) - (-30) - (-15) - 0 - 15 - 30 - 45	°
Collector slope	15 - 30 - 45	°
Specific storage volume	0.05 - 0.15 - 0.4 - 1.1 - 3	m <sup>3</sup> /m <sup>2</sup>
Specific load	200 - 500 - 1500 - 4000 - 10000	KWh/m <sup>2</sup>

→ 145 152 simulations


# The central system | Results



- Radiation on the collector plane
- Collector plant yield
- Efficiency of the collector plant
- Number of stagnation days
- Heat losses through the connection pipes
- Heat losses through the storage
- Number of cycles of the storage
- Efficiency of the storage
- Solar energy delivered to the net
- Auxiliary heat delivered to the net
- Maximal auxiliary boiler power
- System efficiency



# The central system | Results




Evolution of the solar fraction and the solar plant efficiency related to increasing collector area per MWh yearly heat demand for the central system in two different locations and net operation temperatures ( $T_{\text{supply}}/T_{\text{return}}$ ) for 1 200 m<sup>2</sup>.

# Contents

- Development of the tool
  - Distributed system
  - Central system
- Economics and environmental performance

Steinbeis Research Institute  
for Solar and Sustainable  
Thermal Energy Systems  
[www.solites.de](http://www.solites.de)

solites




# Environmental performances

- Primary energy saving rate
- CO<sub>2</sub> equivalent emissions avoided in kg
- Calculation in comparison to a system in which the solar heat would be produced by another energy, called energy of reference (gas, biomass, coal, oil or electricity)

**1 Schritt 1** Eingabe    **2 Schritt 2** Erträge    **3 Schritt 3** Wirtschaftlichkeit & Ökologie    **4 Schritt 4** Ergebnis

**Zentrale Einspeisung mit erdvergrabenen Behälter-Wärmespeicher | Wirtschaftlichkeit und Ökologie**  
Die Wirtschaftlichkeitsberechnung wird vereinfacht nach VDI 2067 unter Berücksichtigung der Hauptkomponenten durchgeführt

Wirtschaftlichkeit		Ökologie	
Spezifische Kollektorkosten in €/m <sup>2</sup>	<input type="text" value="446"/>	Energieträger der Zusatz-Wärmearzeugung	<input type="text" value="Biomasse"/>
Spezifische Speicherbaukosten in €/m <sup>3</sup>	<input type="text" value="521"/>	Nutzungsgrad der Zusatz-Wärmearzeugung in Prozent	<input type="text" value="90"/>
Spezifische Kosten Solarnetz in €/m <sup>Trasse</sup>	<input type="text" value="300"/>	Energieträger der Referenz-Wärmearzeugung	<input type="text" value="Biomasse"/>
Zinssatz in %	<input type="text" value="6"/>	Nutzungsgrad der Referenz-Wärmearzeugung in Prozent	<input type="text" value="90"/>
Brennstoffkosten in €/MWh	<input type="text" value="50"/>		
Kosten für Betriebsstrom in €/MWh <sub>el</sub>	<input type="text" value="50"/>		



# Economics

- Calculations according to VDI 2067
- Default values available for components costs

System	Distributed
Collector area	10 000 m <sup>2</sup>
Location	Stockholm, SE
Collector type	HT Flat-plate
$T_{ws}/T_{ss}/T_{wr}/T_{sr}$	70/70/30/40
Specific collector cost	180 €/m <sup>2</sup>
Interest rate	3 %
Additional charge building/terrain	5 % of the collector investment cost
Additional charge control system	5 % of the collector investment cost
Additional charge system installations	10 % of the collector investment cost
Design	7 % of the total investment cost without design

→ Heat cost: 45 €/MWh

# Economics

System	Distributed
Collector area	10 000 m <sup>2</sup>
Location	Würzburg, DE
Collector type	HT Flat-plate
$T_{ws}/T_{ss}/T_{wr}/T_{sr}$	70/70/30/40
Specific collector cost	246 €/MWh
Interest rate	6%
Additional charge building/terrain	5 % of the collector investment cost
Additional charge control system	5 % of the collector investment cost
Additional charge system installations	10 % of the collector investment cost
Design	7 % of the total investment cost without design
Incentive	40 % on collector cost

→ Heat cost: 74 €/MWh

→ Heat cost: 44 €/MWh

Barcelona without incentives: 42 €/MWh and 53 €/MWh for the highest operation temperatures

# Economics

System	Central
Collector area	10 000 m <sup>2</sup>
Location	Würzburg, DE
Collector type	HT Flat-plate
Specific storage volume	2 m <sup>3</sup> /m <sup>2</sup> <sub>collector area</sub>
Total heat demand	5000 MWh
T <sub>s</sub> /T <sub>r</sub>	70/40 °C
Specific collector cost	246 €/m <sup>2</sup>
Specific storage cost	93 €/m <sup>3</sup>
Specific cost of additional boiler	58 €/kW
Specific connecting pipes cost	300 €/m <sup>2</sup>
Interest rate	6 %
Additional charge building/system installations	12 % of the components investment cost
Additional charge control system	8 % of the components investment cost
Design	10 % of the total investment cost without design
Financial support	40 % of the collector cost and complete storage cost (maximum possible 250 €/MWh)

→ Solar heat cost: 75 €/MWh

→ Solar fraction: 49 %

→ Compared to a 100% gas powered system with a boiler efficiency of 0.9:

- 49 % primary energy savings
- 508 tons of CO<sub>2</sub> equivalent emissions avoided

## Conclusion

- Different level of usage
- Extension possibility
- No replacement of detailed simulations
- Beta version available soon on [www.sdh-online.solites.de](http://www.sdh-online.solites.de)
- German and English versions
- Feedback welcome